



ADDENDUM #2

Date: May 09, 2024

Job No.: RFP 2024 - 03 Housing Heat Pump installations

The following additions, deletions, and changes are to be read with and form part of the original Bid Document. Receipt of the addendum **is the responsibility of the bidder, all addendums made public.** This will serve to answer questions received, answer are in red.

1. Historical electrical loading data will be required for ESA permits. Will Lanark County provide historical electrical loading data for the individual units or provide signed consent forms for access to electricity data? **Historical loading data or access to electricity data will be provided at time of award, if any.**
2. There is an ecobee thermostat at 45E Sussex Street that is suitable for the heat pump installation. Are there ecobees in every unit? **The digital thermostat are not present in every unit, all bidders are to include a proper thermostat, recommended by heat pump manufacturer, with each system installation.**
3. Existing thermostat wire does not seem to be sufficient for heat pumps. Should we allow for new thermostat wire for every unit? **Allow for new wire for every unit.**
4. Is a lineset cover required on the exterior exposed refrigerant lines and electrical wire? **Install as per manufacturer's recommendations. If not required then it does not need to be part of the submission.**

Email submissions only to: ddicaire@lanarkcounty.ca

Proponent's failure to submit their application by the closing date and time will result in their application no longer considered and will be returned unopened.